

OFFICE MEMORANDUM

DATE: December 3, 1998

TO: Bridge Division
FROM: Aileen for ETF *AMS*
SUBJECT: Elastomeric Shop Drawing Review

On all future shop drawings for elastomeric bearings please ensure that the fabricator has provided details on how the bearings are to be marked for proper identification and orientation in the field. An example of these details from Seismic Energy Products, L.P. is attached.

AMS:
cc: Mr. Fain

7/11/9803